

HOLOPHANE WASHINGTON POSTLITE LED SERIES LUMINAIRE or

HOLOPHANE WASHINGTON LED REDTRO_FIT KIT and CITY FIXTURE.

Must include photo-cell and dimming control module.

HOLOPHANE WASHINGTON POSTLITE LED SERIES LUMINAIRE WSE2P5040KASBK3BK4DE(P7)

HOLOPHANE WASHINGTON LED RETRO-FIT KIT


to use with City's Washington Fixtures:

WARETRO2P5040KASBK3NDE(P7) RFD253976


Washington Postlite LED Retrofit 2 (WARETRO2):
Performance Package 50, 4000 Series CCT,
Auto—Sensing Voltage (120—277V), Black,
Asymmetric Type III, Spike finial — no other trim.

ROAM deconode to work with existing photocontrol hole in housing, DCM to connect to dimming leads on driver and be mounted securely to driver bracket, P7 receptacle to be used, dimming leads and extra leads to be capped off.

Packaging to be modified to be more secure to prevent breakage.



HOLOPHANE WASHINGTON POSTLITE LED SERIES LUMINAIRE




DECORATIVE POLE MUST BE BONDED TO THE GROUND ROD.

DECORATIVE STREET LIGHT
SETBACK SIDEWALK INSTALLATION

HOLOPHANE WADSWORTH ALUMINUM POLES: Poles must be 12' in height or 16' in height where necessary to achieve lighting standards.

(SITELINK SHAFT) WDA 12 L4E 17 P07 ABG BK WDA 16 L5J 17 P07 ABG BK

(FLUTED SHAFT)
WDA 12 FJ5 17 PO7 LAB BK
WDA 16 FJ5 17 PO7 LAB BK



CONCRETE FOUNDATION

— 5/8" X 10 FT. GROUND ROD BONDED TO CONDUIT TO PROVIDE 8 FT OF CONTACT WITH SOIL

5/8" X 10 FT. GROUND ROD

GALVANIZED RIGID STEEL OR FIBERGLASS CONDUIT. SIZE AS REQUIRED.

STREET

DECORATIVE POLE MUST BE BONDED TO THE GROUND ROD.

<u>DECORATIVE STREET LIGHT</u>
CURBSIDE SIDEWALK INSTALLATION

(PLACE IN ONE POUR)

POLE BASE PLATE HAS FOUR 2" \times 1" SLOTTED HOLES AT 90'; ACCOMMODATES 3/4" \times 21" \times 3" ANCHOR BOLTS IN 9"-11" BOLT CIRCLE.

ANCHOR BASE ASSEMBLY

NOTE: DRAWING NOT TO SCALE
ALL EVEBOLTS, BOLTS, NUTS, AND WASHERS SHALL BE GALV.
STEEL UNLESS NOTED OTHERWISE, ALL SET SCREWS SHALL BE
MIN. DIA. 1/4" STAINLESS STEEL WITH SOLURE OR HEX HEADS.

He. Pointer/Aloue Date
Thitume and Health, Epitethyatian 65/2020



Know what's **below**.

Call before you dig.

UTILITY LOCATIONS ARE APPROXIMATE. THE CONTRACTOR SHALL BE RESPONSIBLE FOR DETERMINING UTILITY LOCATIONS PRIOR TO BEGINNING OF CONSTRUCTION.
THESE PLANS MAY NOT SHOW ALL UTILITIES OR THE CORRECT LOCATIONS.

Light Detail

Street

ecorative

ty of Springfield



TYP DATE 40 24 2024

EXP DATE: 12-31-2021

Standard Drawing 5-24d

NO SCALE

DRAWN BY: CH
DESIGNED BY: DRB
CHECKED BY: BB

....